



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No. : MCPHL/25/3305

Date : 23.09.2025


Ref. No. : GMHS/34/2025/430	Sample Details	Date & Time
Dated : 16.09.2025		
Issued to : The Headmistress Govt. Model High School Sector - 34-C, Chandigarh	Collected By : Laboratory Staff	Laboratory Staff
Location : From School tap of Govt. Model High School Sector - 34-C, Chandigarh	Collection Date : 18.09.2025	09:00a.m
Packing : Polypropylene and glass bottle	Received at Lab : 09:30a.m.	


Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	—	7.53
2	Odour	Agreeable	—	Agreeable
3	Taste	Agreeable	—	Agreeable
4	Turbidity	<1	N.T.U.	0.7
5	Total Dissolved Solids	<500	mg/l	213
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	182
8	Total Hardness (as CaCO ₃)	<200	mg/l	108
9	Chlorides (as Cl)	<250	mg/l	06
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 09/2025-26/273216 dated 16.09.2025, amount Rs.-3300/-

Note: - Water sample is found " **POTABLE** "



Chemist,
M.C.P.H. Laboratory,
Chandigarh.



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated : 23.09.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.


Chemist,
M.C.P.H. Laboratory,
Chandigarh.


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT